



# Wyoming State Fire Marshal

Occupancy: **Sweet Spirits Child Care**

Occupancy ID: **4744**

Address: **211 E Kelly AVE**

**Jackson WY 83002**

Inspection Type: **Maintenance**

Inspection Date: **11/10/2022**

By: **Adams, Alan**

Time In: **13:00**

Time Out: **13:30**

Authorized Date: **11/11/2022**

By: **Adams, Alan**

Next Inspection Date: **No Inspection Scheduled**

Form: Maintenance E.

## Inspection Description:

Educational Group Occupancies includes, among others, the use of a building or structure, or a portion thereof, by 6 or more persons at any one time for educational purposes through the 12th grade.

## Inspection Topics:

### General Comments

No violations noted at time of inspection.

Passed

**Status: PASS**

**Notes: No violations observed at this time.**

### Fire Protection Systems

901.6, Table; Inspection, testing and maintenance- fire extinguishers-annually w/tags attached

Fire protection systems shall be inspected, tested and maintained in accordance with the referenced standards listed in Table 901.6.1.

**Status: PASS**

**Notes:**

915.1; Carbon Monoxide detection

Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Section 1103.9.

**Status: PASS**

**Notes:**

### Miscellaneous

405.3; Frequency- evacuation drills

Required emergency evacuation drills shall be held at the intervals specified in Table 405.2 or more frequently where necessary to familiarize all occupants with the drill procedure.

**Status: PASS**

**Notes:**

## Additional Time Spent on Inspection:

### Category

### Start Date / Time

### End Date / Time

**Notes:** No Additional time recorded

**Total Additional Time: 0 minutes**

**Inspection Time: 30 minutes**

**Total Time: 30 minutes**

## Summary:


**Overall Result:** Passed

Maintenance and plan review projects when no corrections are needed and all inspections are completed.

**Inspector Notes:** Daycare approved for relicense.

## Inspector:

Name: Adams, Alan  
Rank: Fire Inspector  
Mobile Phone(s): 307-389-2376  
Email(s): alan.adams@wyo.gov  
Adams, Alan:



Signed on: 11/11/2022 08:28

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

## Representative Signature:

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date