CCL-300 08/12

FACILITY VISIT

Facility Name: <u>OUR SAVIOR'S LUTHERAN</u> <u>PRESCHOOL/CHILDCARE</u>

Provider:

Address: 531 SOUTH DURBIN

Facility Type: ____ FCCH ____ FCCC X CCC

Comments/TA Provided:

Out to walkthrough with health, building, fire, and Licensing to see if space can be used for before/after school care. Will need to have a director at this location or Jessica will be at Facility 50%. If bedrooms are going to be used there would be exterior doors to the outside of the building or would need to be sprinkled. Banister needs to be fixed so less that 3 1/2 inch gaps-solid gate or door at top of stairs to the basement. add mop sink, tamper proof outlets, drinking fountain, bull caps, tempering valve on the bathroom sink. CO detector, smoke detectors all rooms, emergency lighting. Health - Utilize other kitchen at main facility, dishes done in 3/complartment sink, and lunches stored. Will need a written plan as to how this will be done. Please call me with any questions.

Dicrector/Providor:	 Date:	
Childcare Licensor:	 Date:	

Certificate #: Phone: 001810 307-57

Date: <u>08/11/2020</u> Time: <u>01:45</u>

Phone: <u>307-577-4006</u>

City: Casper